



# Stormwater BMP Inspection Checklist

## Cisterns

Development Name: \_\_\_\_\_

Address: \_\_\_\_\_

Inspector Name: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

BMP Feature	Potential Problem	Maintenance Needed	✓
Gutters, drains, and spouts	Clogging has occurred	Remove leaves, debris, and other foreign matter and dispose in a manner that will not impact the BMP.	<input type="checkbox"/>
Gutters, drains, and spouts	Any portion of the gutter, drain, or spout is crushed or damaged	Repair or replace as needed.	<input type="checkbox"/>
The tank	Any portion of the structure is cracked or damaged	Repair or replace the structure. An appropriate professional should inspect the structure after the repairs or replacements are made.	<input type="checkbox"/>
Inlet and Outlet pipes	Cracks and other openings greater than 1/16 inch wide	Repair or replace the pipes to prevent mosquitoes.	<input type="checkbox"/>

### Comments

---



---



---