



# Stormwater BMP Inspection Checklist

## Dry Detention Basin

Development Name: \_\_\_\_\_

Address: \_\_\_\_\_

Inspector Name: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

BMP Feature	Potential Problem	Maintenance Needed	✓
The main treatment area	Water is standing for more than 5 days after a storm event	Check outlet structure for clogging. If it is a design issue, consult an appropriate professional.	<input type="checkbox"/>
	Vegetation is less than 4 inches or greater than 8 inches	Mow vegetation to height of approximately 6 inches.	<input type="checkbox"/>

### Comments

---

---

---