



# Stormwater BMP Inspection Checklist

## Sand Filter

Development Name: \_\_\_\_\_

Address: \_\_\_\_\_

Inspector Name: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

BMP Feature	Potential Problem	Maintenance Needed	✓
The adjacent pavement	Sediment is present of the pavement surface	Sweep or vacuum the sediment as soon as possible.	<input type="checkbox"/>
The filter bed and underdrain collection system	Water ponds on the surface for more than 24 hours after a storm event	Check to see if the collector system is clogged and flush if necessary. If water still ponds, remove the top few inches of filter bed media and replace. If water still ponds, then consult and expert.	<input type="checkbox"/>
The drop inlet, vaults, or other underground structure (if applicable)	Any portion of the structure is cracked or damaged	Repair or replace the structure. An appropriate professional should inspect the structure after the repairs or replacements are made.	<input type="checkbox"/>

### Comments

---



---



---